

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1209:173 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: System Sensor, 3825 Ohio Ave, St Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models P1215, P121575, P2415, P241575, P2430, P2460, P2475, P2495 and P24110 horn/strobes with or without suffix -W (white color) and suffix F for FUEGO design, suffix AG for AGENT, suffix EV for EVAC and P for plain plastic housing. Suffix -F, -EV and -AG are available for all models. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Electrical:	-12:	10.5 - 17 VDC
	-24:	20 - 30 VDC
Candela:	-15:	15cd
	-1575:	15cd, 75cd on axis
	-30:	30cd
	-60:	60cd
	-95:	95cd
	-75:	75cd
	-110:	110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. These sounder/strobe combination units are not intended for field assembly.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as horn strobes for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application. For wall mount and indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: Models P1215 and P121575 are NOT intended for Public Mode Fire Alarm Service when used on 12 V control panel at low volume.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager